

"LIST OF ELECTRICAL SPECIFICATION FOR ROSSI RACEWAY PARK"

1) 400 Watt sodium vapour floodlights on a day/light switch. units	1 / 5,5
2) 400 Watt Mercury vapour high bay light fittings.	3/Unit
3) 1500mm 2 tube fluorescent light fitting with diffuser.	3/unit
4) 1200 x 600 recessed three-tube light fitting in exposed-T system.	3/unit
5) 500mm fluorescent light fitting. (kitchen)	1/unit
6) Double 16 Amp plug points.	6/unit
7) Dedicated computer plug points.	6/unit
8) Telephone points.	6/unit
9) 16 Amp single switch socket outlets.	8/unit
10) Connection for hot water cylinder.	1/unit
11) 200 x 150mm Telkom distribution box in reception.	1/unit
12) 80 Amp Eskom distribution board.	1/unit
13) 32 Amp Three Phase plug points	2/unit
14) Ø25, Ø50 and Ø110mm sleeves for various connections.	Item
15) External steel security gate to be fitted with electrical lock, which is linked to the intercom system.	1/unit
16) Rep. door release button linked to intercom.	1/unit
17) Plug point for future A/C Unit.	1/unit